



U.S. DEPARTMENT OF
ENERGY



US DOE Kick-Off Meeting

Enabling Production of Low Carbon Emissions Steel through CO₂ Capture from Blast Furnace (BF) Gases (FE0031937)

Principal Investigator: Atanu Mukherjee

Project Manager: Abhijit Sarkar

Dastur International, Inc.

Sep, 2021




Objectives & Key
Elements of the Study

PMP &
Org. Structure

Research Plan / Project
Scope

Technology
background and
Technical Merits

Preliminary results



1

The steel industry is responsible for ~7-9% of overall carbon emissions worldwide

2

The Blast Furnace is the most carbon intensive operation in ISPs, emitting 1.6 – 2.1 t CO₂ per t of hot metal.

3

The project aims to reduce CO₂ emissions by up to 70% from the 'available' BF gas (425 MMSCFD), resulting in CO₂ capture of 2.4 to 2.8 mtpa

4

Using a novel Fuel Conversion and Carbon Capture scheme, the project aims to capture and sequester CO₂ at a cost of ~ 42 US\$ / tonne CO₂

5

Produce hydrogen for alternative uses in the steel plant in the future

1

Carbon Capture at scale with BF energy transformation for low carbon H₂ heavy fuel to include multiple downstream consumers

2

Flexibility of Design from baseline volume of 2.4 (to 2.8) mtpa CO₂ capture, while optimizing and extracting H₂ heavy fuel for use

3

Optimizing CO₂ Capture Economics (Capex and Opex) based on train capacity, CO₂ concentration and related gas conditioning


4

Flexibility of Design to route conditioned gas blends to maintain operational flexibility and reliability

5


Flexible of Design to extraction of hydrogen for alternative use in steel plant in future


Cliffs Burns Harbor Plant Configuration and Typical CO₂ Emissions (Direct)




Total CO₂ emissions (direct) is ~ 8 mtpa

CO₂ figure Based on EPA number






Project Organization Chart



Project Management Plan: Schedule, Milestones & Deliverables



Continued...

Project Management Plan: Schedule, Milestones & Deliverables



		Months																			
Tasks	Activities	May '21	Jun '21	Jul '21	Aug '21	Sep '21	Oct '21	Nov '21	Dec '21	Jan '22	Feb '22	Mar '22	Apr '22	May '22	Jun '22	Jul '22	Aug '22	Sep '22	Oct '22	Nov '22	
	Deliverables	D1						D2/D3			D4		D5	D6					D7		
Task 4	Studies & Investigations																				
4.1	Steam and Electricity Sourcing Study																				
4.2	Solvent Disposal Investigation																				
4.3	Waste Water Treatment Study																				
4.4	Permitting Study & Review										D4										
4.5	Hazard and Operability Review (HAZOP)													D6							
4.6	Constructability Review												D5								
Task 5	Costing																				
5.1	Capital Cost of Major Equipment incl. Construction Cost																				
5.2	Capital Cost for BoP Facilities incl Construction Cost																				
5.3	Project Indirect Costs																				
5.4	Operating & Maintenance Costs																				
Task 6	Report Submission																				
6.1	Initial Engineering Design and Cost Estimate																	D7			
	Milestone : Initial Engineering Design and Cost Estimate																	M6			
6.2	Techo-economic Analysis																			D8	
6.3	EHS Risk Assessment																			D9	

Milestones	
M1	= Project Team Kick-off Meeting
M2	= Updated PMP
M3	= DoE Kick-Off Meeting
M4	= Preliminary Design Review of CC Island
M5	= Detail Design Review of CC Island
M6	= Initial Engineering Design and Cost Estimate

Deliverables	
D1	= Updated Project Management Plan (PMP)
D2	= Initial Technology Maturation Plan (TMP)
D3	= Data Management Plan
D4	= Permitting Study & Review
D5	= Constructability Review
D6	= HAZOP Review
D7	= Initial Engineering Design and Cost Estimate
D8	= Techo-economic Analysis
D9	= EHS Risk Assessment







Task / Subtask Number	Deliverable Title	Planned Completion Date
1	Project Team Kick-off Meeting	17 May 2021
1.1	Updated Project Management Plan	31 May 2021
1.1	DOE Kick-Off Meeting	21 Sep 2021
2.1	Preliminary design review of CC island	15 Dec 2021
2.2	Detail design review of CC island	15 Apr 2022
6.1	Initial Engineering Design & Cost Estimate	15 Sep 2022





Cost type	Total budget	Share
Federal share	US\$ 1,497,344	80%
Non-federal share	US\$ 377,077	20%
Total	US\$ 1,874,421	100%

Cost type	May '21 – Aug '21	Share	Remaining budget	% Remaining
Federal share	US\$ 384,356	89%	US\$ 1,112,988	74%
Non-federal share	US\$ 47,023	11%	US\$ 330,054	88%
Total	US\$ 431,379	100%	US\$ 1,443,042	77%



Task 1	Project Management <ul style="list-style-type: none">• Project Management Plan• Technology Maturation Plan• Data management Plan	
Task 2	CO₂ Capture (CC) Island Design <ul style="list-style-type: none">• Preliminary Design• Pre-FEED Engg	
Task 3	Balance of Plant Design and Integration with the CC island <ul style="list-style-type: none">• Preliminary Design• Pre-FEED Engg	
Task 4	Studies and Investigations <ul style="list-style-type: none">• Steam and Electricity Sourcing Study• Solvent Disposal Investigation• CO₂ Disposition Study• A Wastewater Treatment Study, permitting study and review, a hazard and operability review (HAZOP) and a constructability review	
Task 5	Detailed Costing of the Project <ul style="list-style-type: none">• Capital Cost of major equipment & BOP including construction costs• Project indirect cost• Operating and maintenance costs	
Task 6	Project Report <ul style="list-style-type: none">• Initial Engineering Design and Cost Estimate• Techno-Economic Analysis (TEA)• Environmental Health and Safety (EH&S) Risk Assessment	





Technical Merits of BF Gas Conditioning through Water Gas Shift




Process

Exothermic Catalytic Reaction:

$$\text{CO} + \text{H}_2\text{O} = \text{CO}_2 + \text{H}_2 + \Delta$$

Feed Gas Preheating



High-quality Steam Generation





Carbon Capture


Facilitates:

- Production of CO₂ rich (> 30 vol.%) gas stream
- Capture of Higher Volumes of CO₂


Lower Equip. sizing & Area Footprint



Lower CapEx & Cost of Capture



Lower Indirect CO₂ emissions





Flexibility

100% Shift


- All CO converted to CO₂
- Enables max. CO₂ capture & H₂ enrichment

Partial Shift

- Allows control over 'H₂/CO'
- Facilitates production of multiple value-added products

By-Pass

- For maintenance of the shift reactors
- During BF downtimes




Value Creation


Energy Dense H₂-rich Cleaner fuel




Pure H₂



Dense stream CO₂



- Proprietary Solvent-based Technology
 - Liquid absorbent-based capture
 - Low aqueous
 - World-wide Patents



Performance Attribute	ICE-21 (2017)	Target Commercial Applications
TRL	6	9
Scale (MWe)	12	300
CO ₂ in flue gas, vol%	13	11.5
Hours of operation	2,750	> 120,000
L/G, mass/mass	2	1.9
CO ₂ Capture Efficiency, %	91	> 95
CO ₂ Product Purity, vol%	99	> 95
Corrosion of 304 (mpy)	0	< 0.1

Accelerated development path leveraging existing research facilities



2010

ION-CE Lab-pilot
Simulated Flue Gas
3 kWe
Boulder, CO, USA



2012

EERC
Coal
0.05 MWe
Grand Forks, ND, USA



2015

NCCC
Coal
0.5 MWe
Wilsonville, AL, USA



2016 - 2017

TCM
Refinery & Natural Gas
30 – 60 ktpa
Mongstad, Norway



2018 - 2021

Commercial FEED
Coal
2 – 5 Mtpa
Sutherland, NE, USA

Much Higher CO₂ Content

- 30% vs. 4-12% CO₂
- Significantly smaller absorber and ducting
- Change from lined concrete vessel to SS304 vessel
- Maximum train size increases (now limited by stripper/compression equipment)

Higher absorber temperatures

- Intercooling is necessary
- Placement of intercooler is important

Low-oxygen environment

- No oxidative degradation leads to change in solvent management strategies
- Possible contaminant concerns in outlet supercritical CO₂ stream (H₂S, CO)


Gas feeds a powerhouse

- Low VOC and Nitrogen emissions


- › Permeable unit that can accept large volumes of CO₂
- › At depth:
 - Below and isolated from (via seal) protected freshwater (>10,000 mg/L)
 - >2400 ft below water table (CO₂ dense phase)
- › Leasable acreage large enough to accept the rates planned
- › Manageable induced seismic risk

Seals
Mt Simon Target


Too shallow



Generalized Stratigraphic Column of the Illinois Basin




- › Existing data compiled by Illinois State Geological Survey
- › Subsurface beneath Cliffs BH facility is marginal for storage:
 - Shallow
 - Salinity uncertain
 - High population
- › More favorable 15-60 miles to south
- › More work required!




- › 2.4 million tonnes per year single source to sink pipeline transport
- › National Energy Technology Laboratory FE/NETL CO₂ Transport Cost Model
- › 15 Miles = \$24M
- › 60 miles = \$70M
- › Savings in scale up (more than one source into pipeline)





Baseline Architecture with BF Gas Characteristics





A


Component	Units	BF Gas (Before Cleaning)
Gas Comp.		
CO	vol. %	22.6
CO ₂	vol. %	22.1
H ₂	vol. %	9.2
N ₂	vol. %	45.5
Gas Temp	°F (°C)	212 (100)
Gas Pressure	Psig (Barg)	13.5 (0.9)
H ₂ /CO		0.41
Gas CV	BTU / ft ³	80-110

Available gas for CCUS scheme:
43,857 mmBTU/day

Existing Project Battery Limit
Proposed



BFG Conditioning & CO₂ Capture: Block Flow Diagram and Preliminary Results




Stream description	Units	BF Gas	Steam to WGSR	Shifted Gas from WGSR	H2 rich fuel gas	Steam to CCU	CO ₂ into compressor	CO ₂ out from compressor
Stream No.		1	2	3	4	5	6	7
Gas Comp. (dry basis)								
CO	vol. %	22.6	0	10	14	0	0	0
CO ₂	vol. %	22.2	0	31	2	0	100	100
H ₂	vol. %	9.2	0	19	27	0	0	0
H ₂ O	vol. %	0	100	0	0	100	0	0
N ₂	vol. %	45.5	0	41	57	0	0	0
Gas CV	BTU/SCF	103	n/a	92	130	n/a	n/a	n/a
Gas Vol. Flow Rate	mmSCFD	425	n/a	475	337	n/a	138	138

considering 2.4 mtpa CO₂ capture capacity




Considerations

- › Feed steam is available at 257 °F (145 °C) and 14.5 psig
- › Feed BFG need to be compressed to 14.5 psig to account for the overall pressure drop
- › Mixture of BFG and Steam need to be heated to 660 °F (350 °C) for the required catalytic activity in the WGSR
- › 36% BFG is by-passed to get optimum result and desired H_2/CO in the outlet



considering 2.4 mtpa CO₂ capture capacity

Water Gas Shift Process Modeling: Preliminary Results ($H_2/CO = 2$)




Increasing Bypass fraction → Decreasing gas volume to be shifted

- Needs more shift in the reactor
- Decreasing compression duty
- Decreasing cooling duty
- Decreasing steam for reaction

- Increasing degree of shift → Increasing exothermic heat → Increasing steam generation (293 F, 60 psia)

Favorable Conditions


- Maximizing the bypass fraction, until the equilibrium limit[†] of the WGS reaction, results in most favorable conditions
- [†] determined by feed gas composition and temperature




36%
Bypass
Fraction




660 °F
Reactor Inlet
temperature




63 klb/h
293 F, 60psia
Steam generated




- Minimum degree of shift – at 0% bypass – increases with H₂/CO
- Maximum degree of shift – bound by the equilibrium limit of WGS reaction
- Maximum bypass – occurs at maximum degree of shift – decreases with H₂/CO




Increasing H₂/CO \rightarrow increasing degree of shift \rightarrow increasing steam generation



- Increasing Bypass \rightarrow decreasing Vol. of gas for compression \rightarrow decreasing compression duty
- Independent of H₂/CO ratio




- Reactor size strongly depends on the H_2/CO – higher H_2/CO requires higher degree of shift.
- No *one-size-fits-all* for reactor size. Fixing one reactor size may result in over sizing of reactor or insufficient shift when targeting various H_2/CO cases



Residence time (deduced from Reactor volume and bypass fraction) plotted against the degree of shift for various cases, collapses all points along one curve. This proves that the overall WGS model is internally consistent


Effect of H₂-rich fuel on Fuel Mix and Gas Pipeline to Power House

Present Scenario



Sl. No.	Fuel	Energy content (mmBTU/day)	% (energy basis)	Volume Flow Rate (ft ³ /day)	% (VFR basis)	Heat Value (BTU/ft ³)
1.	COG	22,052	31%	40,837,037	9%	540
2.	BFG	43,857	63%	402,357,798	90%	103
3.	NG	4,008	6%	3,891,262	1%	1030
	Total	69,917		447,086,097		

Envisaged scenario for 2.4 mtpa capture





Sl. No.	Fuel	Energy content (mmBTU/day)	% (energy basis)	Volume Flow Rate (ft ³ /day)	% (VFR basis)	Heat Value (BTU/ft ³)
1.	COG	22,052	31%	40,837,037	11%	540
2.	H2RF	43,857	63%	337,361,538	88%	130
3.	NG	4,008	6%	3,891,262	1%	1030
	Total	69,917		382,089,838		

No change is envisaged in the NG, COG & H2RF (originally BFG) pipeline sizing

H₂ Combustion Characteristics

Combustion Parameter	Unit	Methane	Hydrogen
Molecular Weight	kg/kmol	16	2
Energy Density	kJ/Nm ³	0.716	0.09
Flame Speed	m/s	0.55	7.7
Air to fuel ratio	kg/kg	20.78	41.2
Higher Heating value	MJ/m ³	39.8	12.7
Lower Heating value	MJ/m ³	35.8	10.8



CFD Modeling

Fluid flow pattern

- Temperature fields
- Velocity fields

Flame Characteristics

- Flame Temperature & Velocity
- Flashbacks
- Air/Fuel Ratio
- Flame Appearance

Combustion Products

- NO_x, SO_x, SPM, etc.
- Extant emission norms to be considered

H₂

Maximum H₂ limit



New 'low-carbon' fuel-mix design



Host



Attendees



1

No overground and underground facilities other than 132 KV transmission line - needs to be relocated during the site work

2

Space available for installation of CHP/boiler to source steam and power

3

BFG tapping can be taken from nearby pipe-rack beside power house


4

15 PSI.g saturated steam available from power house for the project

5


New NG pipeline to be laid for additional natural gas requirement

1 With Boiler




NG required : 19,337 mmBTU/d
Grid power : 40 MW

2 With CHP




NG required : 23,957 mmBTU/d
Grid power : Zero

3 With WHR +Boiler/CHP



NG required : To be studied
Grid power : To be studied

4 With Gas turbine + HRSG



NG required : To be studied
Grid power : To be studied

Potential steam generation from CDQ, BOF gas recovery system and other options
* Numbers are based on 2.4 mtpa capture

BFG volume considered: 43,857 MMBTU/d

Parameter	Option 1 – With CHP	Option 2 – with Boiler	Unit
CO ₂ Captured	2.4	2.4	MTCO ₂ /year
Total CAPEX	450	430	\$MM
Annualization Factor	0.0944	0.0944	-
Amortized CAPEX	17.7	16.9	\$/tonne CO₂
Annual OPEX	42.0	60.5	\$MM/year
OPEX/Cash Cost	17.5	25.2	\$/tonne CO₂
Capture cost incl. CAPEX	35.2	42.1	\$/tonne CO₂
Transport, Sequestration & Monitoring (TSM)	10	10	\$/tonne CO ₂
Total Cost	45.2	52.1	\$/tonne CO₂


Goal of ~\$32 \$/t by commissioning

- Increase in CO₂ volume will amortize same capex over higher volumes
- Onsite wells being explored as an alternative to off site sequestration.
- Steam generation from WGS and other waste heat schemes can complement the net steam requirement of CCU reboiler

Assumptions @ \$70/MWh electricity cost at BH, 90% uptime, 95%+ capture

*Includes capital cost of Water Gas Shift, CHP for carbon capture needs, NG fuel costs at 3\$/Mmbtu

**Includes cost for carbon capture, carbon compression up to 2215 psia





DASTUR

Dastur International, Inc.

www.dastur.com

Principal Investigator

Atanu Mukherjee

Atanu.M@dastur.com

Project Manager

Abhijit Sarkar

Abhijit.sr@dastur.com